

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180731-E497829  
**Report Reference** E497829-20180430  
**Issue Date** 2018-JULY-31

**Issued to:** Traco Power Solutions Ltd  
WHITEMILL INDUSTRIAL ESTATE, WEXFORD IRELAND

**This is to certify that  
representative samples of**

**POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS  
FOR USE IN HAZARDOUS LOCATIONS**

USL, CNL - Power Circuit and Motor-mounted Apparatus  
for use in Hazardous Locations, Class I, Division 2, Groups  
A, B, C and D.

Open Type, Switching Power Supply - Models TIB080-  
112EX, TIB080-124EX, TIB080-148EX, TIB120-112EX,  
TIB120-124EX, TIB120-148EX, TIB240-124EX, TIB240-  
148EX, TIB480-124EX and TIB480-148EX. May be  
followed by up to 6 additional characters which can be a-z  
or 0-9 for traceability only, no impact on safety.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

Standard No. UL 121201: Nonincendive Electrical  
Equipment for Use in Class I and II, Division 2 and Class III,  
Divisions 1 and 2 Hazardous (Classified) Locations  
Standard No. CSA C22.2 No. 213-17 : Nonincendive  
electrical equipment for use in Class I and II, Division 2 and  
Class III, Divisions 1 and 2 hazardous (classified) locations

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

